



- NOTES:
- TERMINAL SCREW TIGHTENING TORQUE:
    - 6 - 4 (45) in-lbs MAX
    - 2 - 0 (50) in-lbs MAX
  - WIRE RANGE: 6 - 0 AWG

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU (EUROPEAN UNION) DIRECTIVE RoHS		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .03 [0.76] 3 PLACE .XXX: ± .010 [0.254]		MTE AN BL POWER ELECTRONICS COMPANY N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200		3 PHASE REACTOR	
		DRAWN BF	DATE 01/23/09	SIZE D	
		CHECKED TM	DATE 10/22/12	DWG No. CD RLW-005505	
		APPROVED TM	DATE 10/22/12	REV 04	
		SCALE 5:6		SHEET 1 OF 1	