



APPROX. WEIGHT (LBS)
1091


ECO No	DESCRIPTION	REV BY	DATE
M9831	REPLACED CAPPANEL-574 WITH 574C	MN	08/08/16




FRONT VIEW
(PANELS REMOVED)




(3 PLACES)




(3 PLACES)




SIDE VIEW





CUSTOMER CONNECTION
DETAIL VIEW (THERMAL)



CUSTOMER CONNECTION
DETAIL VIEW




BOTTOM VIEW



TOP VIEW
(PANELS REMOVED)

NOTES:

1. TIGHTEN TERMINAL BLOCK SCREWS TO 16 IN/LBS. TORQUE.
2. TERMINAL WIRE SIZE: 4 - 14 AWG

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION		
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION		
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .01 [0.25] 3 PLACE .XXX: ± .005 [0.127]	 <div>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200</div>	DRAWN	DATE	MATRIX AP 482A 600V 60HZ FILTER, NEMA 1/2 ENCL		
		SU	05/16/13			
		CHECKED	DATE			
		JM	08/16/16			
		APPROVED	DATE	SIZE	DWG No.	REV
		JM	08/16/16	D	CD MAPG0482E	05
				SCALE	1:8	SHEET 1 OF 1