| WEIGHT (LBS) |
|---|
| 327 |

| ECO No | DESCRIPTION | REV BY | DATE |
|---|---|---|---|
| M9818 | REPLACED CAPPANEL-604 WITH CAPPANEL-568C | SL | 09/20/16 |




FRONT VIEW
(FRONT PANEL REMOVED)




RIGHT SIDE VIEW




DETAIL A
CUSTOMER CONNEVTION
DETAIL VIEW (THERMAL)






**LUG VIEW**
**(TYP 6 PLACES**
**U1, V1, W1**
**U2, V2, W2 TERMINALS)**




BOTTOM VIEW




TOP VIEW
(TOP HAT REMOVED)




**NOTES:**
1. **TIGHTEN TERMINAL BLOCK SCREWS TO 16 IN\LBS, TORQUE.**
2. **TERMINAL WIRE SIZE: 14 AWG.**
3. **TERMINAL WIRE SIZE: 2X 4 AWG.**
4. **TIGHTEN TERMINAL BLOCK SCREWS TO 200 IN/LBS. TORQUE, MA**

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2

CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:

ANGLES: ± 1 °

1 PLACE .X: ± .1 [2.5]

2 PLACE .XX: ± .03 [0.76]

3 PLACE .XXX: ± .010 [0.254]

MTE
POWER QUALITY. SOLVED.

N83 W13330 Leon Road
Menomonee Falls, WI 53051 USA
800.455-4683
262.253.8200

MATERIAL

| | | |
|---|---|---|
| DRAWN | MN | DATE 09/04/13 |
| CHECKED | JM | DATE 09/22/16 |
| APPROVED | JM | DATE 09/22/16 |

CONFIDENTIAL AND PROPRIETARY INFORMATION
THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION

DESCRIPTION

SWG 160A 380-480V 2-8kHz
FILTER NEMA 1/2

| SIZE | DWG No. | REV |
|---|---|---|
| D | CD SWGG0160D | 03 |

SCALE 1:5 SHEET 1 OF 1