

WEIGHT (LBS)
340

ECO No	DESCRIPTION	REV BY	DATE
M9818	REPLACED CAPPANEL-604 WITH CAPPANEL-568C	SL	09/20/16

D

C

B


A

D


C

B


A




FRONT VIEW
(FRONT PANEL REMOVED)




RIGHT SIDE VIEW




BOTTOM VIEW





TOP VIEW
(TOP HAT REMOVED)



LUG VIEW
(TYP 6 PLACES
U1, V1, W1
U2, V2, W2 TERMINALS)



DETAIL A



CUSTOMER CONNECTION
DETAIL VIEW

- NOTES:
1. TIGHTEN TERMINAL BLOCK SCREWS TO 16 IN/LBS. TORQUE.
 2. TERMINAL WIRE SIZE: 4-14 AWG.
 3. TERMINAL WIRE SIZE: 6 AWG - 350 MCM.
 4. TIGHTEN TERMINAL BLOCK SCREWS TO 200 IN/LBS. TORQUE.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU (EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:		DRAWN MN		DATE 09/04/13	
ANGLES: ± 1 °		CHECKED JM		DATE 09/22/16	
1 PLACE .X: ± .1 [2.5]		APPROVED JM		DATE 09/22/16	
2 PLACE .XX: ± .03 [0.76]				SIZE D	
3 PLACE .XXX: ± .010 [0.254]				DWG No. CD SWGW0160D	
				REV 03	
				SCALE 1:5	
				SHEET 1 OF 1	

MTE
POWER QUALITY. SOLVED.

N83 W13330 Leon Road
Menomonee Falls, WI 53051 USA
800.455-4683
262.253.8200

SWG 160A 380-480V 2-8kHz
FILTER NEMA 3R